

CONTRACTOR NOTES:

1. ALL SUBSTRUCTURES SHOWN ARE APPROXIMATE LOCATIONS ONLY, PER AVAILABLE RECORDS.
2. CONTRACTOR TO VERIFY LOCATION OF ALL SUBSTRUCTURES PRIOR TO EXCAVATION.
3. FOR LOCATING EXISTING SUBSTRUCTURES CALL- UNDERGROUND SERVICE ALERT **1-800-422-4133** TWO DAYS BEFORE YOU DIG
4. MINIMUM OF 3' SEPARATION FROM POWER TRANSFORMER LOCATIONS, & STREET LIGHTS UNLESS OTHERWISE NOTED. 1' FROM WALLS, HANDHOLES & CABLE TYPE PEDASTALS.
5. MINIMUM OF 5' SEPARATION FROM FIRE HYDRANTS.
6. DO NOT DEVIATE FROM PLACEMENT OF HAND HOLES INCLUDING THE DIRECTION OF THEIR LENGTH.

REDLINE CALL OUTS:

- A** A.T.&T. POINT OF CONNECTION PICK UP PLACE 1-4" RISER FLUSH WITH POLE LEAVING CLIMBING SPACE ON ONE SIDE OF POLE
- B** DEVELOPER TO PLACE 4' X 8' X 3/4" FIRE RATED BACKBOARD EQUIPPED WITH #6 GROUND WIRE TERMINATED WITH GROUND BUS ON THE BOARD.
- C** DEVELOPER TO PLACE GFI OR STANDARD 110/120V OUTLET. NOT EXCEED 5 FT FROM ATT WALL MOUNTED POWER UNIT.
- D** DEVELOPER TO PLACE 24"X36"X48" HAND HOLE
- E** DEVELOPER TO PLACE 1-4" CONDUIT C PVC WITH NO MORE THAN 3 90 DEGREE BENDS. PLACE 3/8" POLYPROPYLENE PULL LINE OR EQUIVALENT STRENGTH MULE TAPE. CONDUIT ENTER/EXIT THROUGH ENDS OF 2'X3' ONLY. NO CONDUIT TO ENTER/EXIT THROUGH BOTTOMS OR SIDES OF HAND HOLE.

DEVELOPER TO PROVIDE AT&T WITH ACURATE FOOTAGES FROM MULE TAPE AT THE TIME OF INSPECTION, PRIOR TO SERVICE BEING ESTABLISHED

EXCH. RIVERISDE GEO/CO LB29
ENGR: JAN VESSELS TELEPHONE: 951-354-5492

